

Number	KIP-15178/E	Replaces	---
Issued	11-11-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2001328	Page	1 of 2
PIN	0476CR1328		

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the products

Central heating condensing boilers

Trade mark: **IMMERGAS**
Models: *as specified in the Annex 1*

Manufactured by **IMMERGAS S.p.a.**
Brescello (RE), Italy

Have achieved the following (see Annex 1) full and part load efficiencies.



The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012 + A1:2015
EN 15502-2-1 :2012

The validity of this certificate can be verified by means of a register available on the website www.kiwa.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl
Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

Chief Operating Officer
Giampiero Belcredi



Organismo Notificato n. 0476



SGQ N° 007A SSI N° 006G
SGA N° 010D FSM N° 004I
PRD N° 069B



Number	KIP-15178/E	Replaces	---
Issued	11-11-2016	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2001328	Page	2 of 2
PIN	0476CR1328		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 1

Models:

	Magis Combo	Magis Combo Plus
η_{100}	96,3 %	96,3 %
η_{30}	106,1 %	106,1 %
η_4	86,7 %	86,7 %
η_1	95,5 %	95,5 %
P_4	24,0 kW	24,0 kW
P_1	n.t.	n.t.
C.Heater?	Yes	Yes
B ₁ Boiler?	no	no
Type of boiler:	"Condensing"	"Condensing"

Note:

η_{100} = At rated heat output and high-temperature regime - NCV (*)
 η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**)
 η_4 = At rated heat output and high-temperature regime - GCV (*)
 η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**)
 P_4 = At rated heat output and high-temperature regime (*)
 P_1 = At 30 % of rated heat output and low-temperature regime (**)
 C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)
 B₁ Boiler = B₁ according CEN/TR 1749:2014
 Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or "Other Boiler"

Efficiency's values have been measured with gas G20.
(n.t.= not tested)

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)
Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
 (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Certificate

Number KIP-15178/G Replaces ---
 Issued 11-11-2016 Scope Directive 2009/142/EC
 Report 2001328 Page 1 of 1
 PIN 0476CR1328

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia hereby declares that the products

Central heating condensing boilers

Trade mark: **IMMERGAS**
 Models: Magis Combo, Magis Combo Plus
 Manufactured by **IMMERGAS S.p.a.**
 Brescello (RE), Italy

meets the essential requirements as described in the
Directive on appliances burning gaseous fuels 2009/142/EC

Mentioned products have been approved for

Appliance type: B₂₃, B₃₃, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃
 C_{13X}, C_{33X}, C_{43X}, C_{53X}, C_{83X}, C_{93X}
 Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB,
 GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT,
 RO, SE, SI, SK, TR

Related to the following gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	B	30		
H	20,25	B/P	30		
Esi ,E(S)	20/25	P	37		


The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012 + A1:2015
 EN 15502-2-1:2012

*The validity of this certificate can be verified by means of a register available on the website www.kiwa.it
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia*

Chief Operating Officer
 Giampiero Belcredi





Organismo Notificato n. 0476

Kiwa Cermet Italia S.p.A.
 Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl
 Via Cadriano, 23
 40057 Granarolo dell'Emilia (BO)
 Unità locale
 Via Treviso 32/34
 31020 San Vendemiano (TV)
 Tel +39.0438 411755
 Fax +39.0438 22428
 E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it



Certificate



Number	KIP-16884/G	Replaces	---
Issue date	05-07-2021	Contract number	I6700
Due date	04-07-2031	Scope	(EU) 2016/426 (9 March 2016)
Report number	2001328/5	Module	B (Type testing)
PIN	0476CR1328		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

UI MC AP, UI MCP AP

Manufacturer

Immergas S.p.A.
Via Cisa Ligure, 95
42041, Brescello (RE), Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

Chief Operating Officer

Giampiero Belcredi

Digitally signed by: BELCREDI GIAMPIERO
Date: 05/07/2021 14:07:08



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



Number KIP-16884/G **Page** 1 of 1
Issue date 05-07-2021 **Scope** (EU) 2016/426 (9 March 2016)
Due date 04-07-2031 **Module** B (Type testing)
Report number 2001328/5
PIN 0476CR1328

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
Immergas

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
UI MC AP	32,90 – 5,5	32,90 – 5,5
UI MCP AP	32,90 – 5,5	32,90 – 5,5

Appliance types:

B23, B33, B53P, C13, C33, C43, C53, C63, C83, C93, C13X, C33X, C43X, C53X, C63X, C83X, C93X

Countries:


AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	ESi	20/25	M	20
H	20; 25	E(S)	20	P	37

Remarks:

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
 Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-16884/E	Replaces	---
Issue date	05-07-2021	Contract number	I6700
Report number	2001328/5	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476CR1328	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boilers), type(s):

UI MC AP, UI MCP AP

Manufacturer

Immergas S.p.A.
Via Cisa Ligure, 95
42041, Brescello (RE), Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard: EN 15502-1:2012+A1:2015, EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Digitally signed by: BELCREDI GIAMPIERO
Date: 05/07/2021 14:06:44

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it
www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



Number	KIP-16884/E	Page	1 of 1
Issue date	05-07-2021	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2001328/5	Module	B (Type testing)
PIN	0476CR1328		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
Immergas

Specifications:
Model(s):

UI MC AP, UI MCP AP

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	n.t.	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,3	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.